

World Harmonized Duty Cycle (WHDC) Test Programme on WHDC Option No. 5

Final Report
Version 1

26th WHDC Meeting
13th January 2009
Geneve



PM variables to be investigated - I

• 47 mm vs. 70 mm filter size for

- TX40 EMFAB (PTFE coated glass fibre) and
 - TEFLO Filter using bonded ring (PTFE membrane)
- => 70 mm TEFLO filter with ring not available

• Correlation

- Partial and full flow systems for PM.
- Full flow sampling and raw gas sampling for gaseous components.
- CPC according to PMP at full flow and partial flow system for at least 7 cycles.

• Sampling probes

- CVS PM probe with 8 mm internal diameter to be used (min. 12 mm requested by current EC regulation).
- Partial flow PM probe min. 4mm according to WHDC GTR



PM variables to be investigated - II

Influence of sampling system residence time and filter face velocity

- Requested residence time for dilution systems 1 to 5 seconds from inlet of tunnel until filter face for full flow and partial flow system.
- For CVS at least 0.5 seconds residence time for secondary dilution.
- On CVS (FF) two different CVS flow with one Filter Face Velocity.
- CVS flow constant, FFV variation via Gprobe.
- On partial flow system G_{tot} variation => FFV / Residence time variation.

Other sampling conditions

- Sample line length for partial flow system as short as possible.
- Dilution ratio minimum at full load between 5:1 – 7:1 with at least 2:1 in pri. tunnel
- Variation in partial flow system via G_{dil} with $G_{tot} = \text{const.}$ (FFV / FFT = const.) to archive 5:1 and 10:1 overall dilution ration in the partial flow system



Test engines – Test cycles

• Engine No. 1

- IVECO F4AE with SCRT System, Euro V / EEV
- $V_H = 5883 \text{ cm}^3$, $P = 205 \text{ kW}$ @ 2500 1/min

• Engine No. 2

- Mercedes Benz OM501 with SCR System, Euro V / EEV
- $V_H = 11946 \text{ cm}^3$, $P = 350 \text{ kW}$ @ 1800 1/min

• WHTC, every first cycle per day cold, all other hot and WHSC

- Each test to be run 7 times (at least)
- Pre-conditioning for the cold cycle to be performed as last cycle per day
- Soak Time to be considered: 10 min



Parameter set-up – Engine I

Full flow / CVS (FF)												
variation [-]	filter [mm]	venturi [-]	Glot [g/s]	FFV [cm/s]	dilution		r [%]	CVS Distance: mixer - probe [cm]	SPC Distance: probe inlet - filter [cm]	CVS Residence time [s]	SPC Residence time [s]	total CVS flow [kg/h]
					prim.	sec.						
1	47	1+2	0,9	63	3:1	2:1	6:1	360	see sheet "Residence time SPC"	0,39	2,02	2,41
	26										2,29	2,68
2	47	1+3	1,4	98	6:1	-	6:1	360	see sheet "Residence time SPC"	0,23	1,95	2,34
3	47										63	1,37
4	47	98	1,30	1,53								
				Limitation: max. 100 cm/s	Limitation: min. 2:1	Limitation: 5:1 - 7:1				Limitation: mind. 0,5 s	Requested: 1 - 5 s	

Partial flow (PF)												
variation [-]	filter [mm]	Glot [g/s]	q [-]	FFV [cm/s]	r [%]	SPC		CVS Distance: mixer - probe [cm]	SPC Distance: probe inlet - filter [cm]	CVS Residence time [s]	SPC Residence time [s]	total CVS flow [kg/h]
						Distance: probe inlet - filter [cm]	Residence time [s]					
1	47	0,9	5	63	0,06	see sheet "Residence time SPC"	1,65	360	see sheet "Residence time SPC"	1,93	1,06	- 4000
	26											
2	47	1,4	10	98	0,093	1,65	1,06					
3	47	0,9	10	63	0,03	1,65	1,06					
4	47	1,4	10	98	0,046	1,65	1,06					
				Limitation by SPC: 0,8 - 2,0 g/s	Limitation: max. 100 cm/s					Requested: 1 - 5 s		
47		0,8		56								
70		2,0		139								
70		0,8		23								
70		2,0		57								

TUV NORD

Parameter set-up – Engine II

Full flow / CVS (FF)												
variation [-]	filter [mm]	venturi [-]	Glot [g/s]	FFV [cm/s]	dilution		r [%]	CVS Distance: mixer - probe [cm]	SPC Distance: probe inlet - filter [cm]	CVS Residence time [s]	SPC Residence time [s]	total CVS flow [kg/h]
					prim.	sec.						
1	47	2+3	0,9	63	3,4:1	1,8:1	- 6:1	360	see sheet "Residence time SPC"	0,16	2,02	2,18
	26										2,29	2,45
2	47	1+2+3	1,4	98	4:1	1,5:1	- 6:1	360	see sheet "Residence time SPC"	0,14	1,95	2,11
3	47										63	1,37
4	47	98	1,30	1,44								
				Limitation: max. 100 cm/s	Limitation: min. 2:1	Limitation: 5:1 - 7:1				Limitation: mind. 0,5 s	Requested: 1 - 5 s	

Partial flow (PF)												
variation [-]	filter [mm]	Glot [g/s]	q [-]	FFV [cm/s]	r [%]	SPC		CVS Distance: mixer - probe [cm]	SPC Distance: probe inlet - filter [cm]	CVS Residence time [s]	SPC Residence time [s]	total CVS flow [kg/h]
						Distance: probe inlet - filter [cm]	Residence time [s]					
1	47	0,9	5	63	0,034	see sheet "Residence time SPC"	1,65	360	see sheet "Residence time SPC"	1,93	1,06	- 8400
	26											
2	47	1,4	10	98	0,052	1,65	1,06					
3	47	0,9	10	63	0,017	1,65	1,06					
4	47	1,4	10	98	0,026	1,65	1,06					
				Limitation by SPC: 0,8 - 2,0 g/s	Limitation: max. 100 cm/s					Requested: 1 - 5 s		
47		0,8		56								
70		2,0		139								
70		0,8		23								
70		2,0		57								

TUV NORD

Results

1. Gaseous Components

Overview

NO_x Comparison CVS (FF) vs. raw gas (PF)

CO₂ Comparison CVS (FF) vs. raw gas (PF)

2. PM - Particulate Matter

Overview

Parameter Variations

Teflo vs. TX sampling filter



Results - Engine I - Gaseous Components - Overview 1

All WHTC cold + hot, CoV not to be used

	diluted gas [g/kWh]				raw gas [g/kWh]				perc. dev. (FF as basis)			
	HC	CO	NO _x	CO ₂	HC	CO	NO _x	CO ₂	HC	CO	NO _x	CO ₂
arithmetic mean, all c+h	0,042	0,091	2,517	720,0	0,006	0,103	2,540	724,4	-	18,9	1,3	0,6
standard deviation, all c+h	0,0161	0,0494	0,8416	9,1033	0,0025	0,0506	0,8396	9,5913				
coeffi. of variance, all c+h	38,10	54,23	33,44	1,26	43,21	49,31	33,06	1,32				

CVS and raw gas show remarkable good agreement for NO_x and CO₂.



Results - Engine I - Gaseous Components - Overview 2

All WHTC hot (all hot with pre-conditioning, see slide NOx comparison)

	diluted gas [g/kWh]				raw gas [g/kWh]				perc. dev. (FF as basis)			
	HC	CO	NOx	CO2	HC	CO	NOx	CO2	HC	CO	NOx	CO2
arithmetic mean, only h	0,040	0,069	2,050	718,7	0,005	0,077	2,079	722,8		16,2	1,4	0,5
standard deviation, only h	0,0165	0,0142	0,1494	8,1772	0,0011	0,0103	0,1596	8,4496				
coeff. of variance, only h	41,14	20,59	7,29	1,14	24,15	13,36	7,68	1,17				

CoV for CVS and raw gas well below 10 for NO_x and CO₂.

CVS and raw gas show remarkable good agreement for NO_x and CO₂.



Results - Engine I - Gaseous Components - Overview 3


All WHSC (hot)

	diluted gas [g/kWh]				raw gas [g/kWh]				perc. dev. (FF as basis)			
	HC	CO	NOx	CO2	HC	CO	NOx	CO2	HC	CO	NOx	CO2
arithmetic mean value	0,028	0,066	2,478	677,2	0,003	0,064	2,546	683,4	-	-0,3	2,7	0,9
standard deviation	0,0106	0,0101	0,0894	5,4621	0,0059	0,0082	0,0811	8,8654				
coefficient of variance	37,97	15,27	3,61	0,81	171,25	12,83	3,19	1,30				

CoV and percentage deviation good to very good for NO_x and CO₂.




Engine I – Gas. Components - NO_x Comparison CVS (FF) vs. raw gas (PF) - 1




TUV NORD

Engine I – Gas. Components - NO_x Comparison CVS (FF) vs. raw gas (PF) – 2




TUV NORD


Engine I – Gas. Components - NO_x Comparison CVS (FF) vs. raw gas (PF) – 3




Engine I – Gas. Components - CO₂ Comparison CVS (FF) vs. raw gas (PF) - 1



Engine I – Gas. Components - CO₂ Comparison CVS (FF) vs. raw gas (PF) - 2



Engine I – Gas. Components - CO₂ Comparison CVS (FF) vs. raw gas (PF) - 3



Results - Engine II - Gaseous Components - Overview 1

All WHTC cold + hot, CoV not to be used

	diluted gas [g/kWh]				raw gas [g/kWh]				perc. dev. (FF as basis)			
	HC	CO	NOx	CO2	HC	CO	NOx	CO2	HC	CO	NOx	CO2
arithmetic mean, all c+h	0,047	2,687	2,699	670,4	0,017	2,562	2,770	672,7	-	-4,3	2,5	0,3
standard deviation, all c+h	0,0146	0,1925	1,1863	6,6809	0,0030	0,2001	1,2127	6,4131				
coeff. of variance, all c+h	31,34	7,16	43,96	1,00	17,63	7,81	43,78	0,95				

CVS and raw gas show good to very good agreement for NO_x, CO and CO₂.



Results - Engine II - Gaseous Components - Overview 2

All WHTC hot (all hot with pre-conditioning, see slide NOx comparison)

	diluted gas [g/kWh]				raw gas [g/kWh]				perc. dev. (FF as basis)			
	HC	CO	NOx	CO2	HC	CO	NOx	CO2	HC	CO	NOx	CO2
arithmetic mean, only h	0,048	2,698	1,822	668,3	0,015	2,584	1,867	671,0	-	-3,8	2,6	0,4
standard deviation, only h	0,018	0,190	0,124	4,1951	0,004	0,170	0,185	4,7255				
coeff. of variance, only h	36,98	7,05	6,82	0,63	6,00	6,57	9,92	0,70				

CoV for CVS and raw gas well below 10 for NO_x, CO and CO₂.
HC CoV much better for PF System.

CVS and raw gas show remarkable good agreement for NO_x, CO and CO₂.




Results - Engine II - Gaseous Components - Overview 3

All WHSC (hot)


	diluted gas [g/kWh]				raw gas [g/kWh]				perc. dev. (FF as basis)			
	HC	CO	NOx	CO2	HC	CO	NOx	CO2	HC	CO	NOx	CO2
arithmetic mean value	0,034	0,553	1,301	632,3	0,007	0,539	1,342	629,6	-	-2,3	3,6	-0,4
standard deviation	0,018	0,038	0,090	3,262	0,002	0,014	0,132	3,924				
coefficient of variance	52,84	6,80	6,88	0,52	29,40	2,67	9,85	0,62				




Engine II – Gas. Components - NO_x Comparison CVS (FF) vs. raw gas (PF) - 1




Engine II – Gas. Components - NO_x Comparison CVS (FF) vs. raw gas (PF) - 2




Engine II – Gas. Components - NO_x Comparison CVS (FF) vs. raw gas (PF) - 3




Engine II – Gas. Components - CO2 Comparison CVS (FF) vs. raw gas (PF) - 1



Engine II – Gas. Components - CO2 Comparison CVS (FF) vs. raw gas (PF) - 2



Engine II – Gas. Components - CO₂ Comparison CVS (FF) vs. raw gas (PF) - 3



Gaseous Components - Conclusions

The gaseous components NO_x, CO, HC and CO₂ sampled in the raw exhaust according to ISO 16183 respectively GTR No. 4 showed again good to very good agreement when compared to the CVS procedure (sampling in diluted exhaust gas).

The coefficient of variation showed good to very good repeatability. The NO_x and CO₂ CoV's for the raw gas sampling are on the same level as for the CVS.

For the very low emission values of HC and CO (aftertreatment) the raw gas sampling showed better applicability based on the CoV than the CVS.

Since both engines were equipped with SCR systems the pre-conditioning has significant influence on the test-to-test repeatability.



Results - Engine I – Particulate Matter - Overview 1

Variation	FF		FF		PF		PF		diluted gas, PM FF [g/kWh]		raw gas, PM PF [g/kWh]						
	Filtertype	Filtertype	Index Gtot CVS flow (venturi comb.) Index CVS flow r [%]	Index Gtot CVS flow (venturi comb.) Index CVS flow r [%]	Index DF r [%]	Index DF r [%]	Index DF r [%]	Index DF r [%]	PMm 1.	PMm 2.	PMm 1.	PMm 2.					
results WHTC cold																	
1	TX47	TX47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,006	0,006	0,007	0,007
2	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,004	0,004	0,004	0,004
3	0	0	0,9	1 1+3	2	0,046	63	1	0,9	10	2	0,03	63	0,006	0,006	0,008	0,006
4	0	0	0,9	1 1+3	2	0,046	63	1	0,9	5	1	0,06	63	0,005	0,004	0,005	0,005
5	0	0	1,4	2 1+3	2	0,072	98	2	1,4	10	2	0,046	98	0,004	0,005	0,006	0,005
6	TX70	TX70	0,9	1 1+2	1	0,42	26	3	0,9	5	1	0,06	26	0,005	0,005	0,008	0,008
7	TEF47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,026	0,030	0,030	0,038
8	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,013	0,000	0,023	0,003
9	TX47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,004	0,004	0,045	0,000
results WHTC hot																	
1	TX47	TX47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,005	0,005	0,006	0,006
2	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,004	0,004	0,003	0,003
3	0	0	0,9	1 1+3	2	0,046	63	1	0,9	10	2	0,03	63	0,004	0,004	0,005	0,006
4	0	0	0,9	1 1+3	2	0,046	63	1	0,9	5	1	0,06	63	0,004	0,004	0,005	0,004
5	0	0	1,4	2 1+3	2	0,072	98	2	1,4	10	2	0,046	98	0,003	0,003	0,004	0,004
6	TX70	TX70	0,9	1 1+2	1	0,42	26	3	0,9	5	1	0,06	26	0,005	0,005	0,006	0,006
7	TEF47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,035	0,030	0,025	0,025
8	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,013	0,002	0,021	0,002
9	TX47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,004	0,004	0,027	0,013
results WHSC																	
1	TX47	TX47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,006	0,006	0,006	0,006
2	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,004	0,004	0,003	0,003
3	0	0	0,9	1 1+3	2	0,046	63	1	0,9	10	2	0,03	63	0,006	0,006	0,006	0,006
4	0	0	0,9	1 1+3	2	0,046	63	1	0,9	5	1	0,06	63	0,005	0,005	0,005	0,004
5	0	0	1,4	2 1+3	2	0,072	98	2	1,4	10	2	0,046	98	0,003	0,003	0,003	0,003
6	TX70	TX70	0,9	1 1+2	1	0,42	26	3	0,9	5	1	0,06	26	0,009	0,009	0,008	0,008
7	TEF47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,018	0,016	0,013	0,013
8	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,006	0,002	0,026	0,002
9	TX47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,005	0,004	0,009	0,001

All mean values over all parameter variations.




Results - Engine I – Particulate Matter – Parameter variations WHTC 1

Mean values (WHTC hot)																																
Variation	FF		FF		PF		PF		diluted gas, PM FF [g/kWh]				raw gas, PM PF [g/kWh]																			
	Filtertype	Filtertype	Index Gtot CVS flow (venturi comb.) Index CVS flow r [%]	Index Gtot CVS flow (venturi comb.) Index CVS flow r [%]	Index DF r [%]	Index DF r [%]	Index DF r [%]	Index DF r [%]	HC	CO	NOx	CO2	PMm 1.	PMm 2.	HC	CO	NOx	CO2	PMm 1.	PMm 2.												
1	TX47	TX47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,037	0,067	2,376	718,248	0,005	0,005	0,004	0,077	2,498	723,763	0,006	0,006							
2	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,035	0,069	2,052	719,057	0,004	0,004	0,005	0,084	2,053	725,282	0,003	0,003							
3	0	0	0,9	1 1+3	2	0,046	63	1	0,9	10	2	0,03	63	0,066	0,055	2,257	718,922	0,004	0,004	0,005	0,087	2,309	721,486	0,005	0,006							
4	0	0	0,9	1 1+3	2	0,046	63	1	0,9	5	1	0,06	63	0,063	0,071	2,156	731,960	0,004	0,004	0,004	0,084	2,147	725,535	0,005	0,004							
5	0	0	1,4	2 1+3	2	0,072	98	2	1,4	10	2	0,046	98	0,061	0,085	2,056	716,170	0,003	0,003	0,005	0,076	2,049	715,352	0,004	0,004							
6	TX70	TX70	0,9	1 1+2	1	0,42	26	3	0,9	5	1	0,06	26	0,032	0,065	2,161	706,210	0,005	0,005	0,004	0,075	2,241	716,145	0,006	0,006							
7	TEF47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,036	0,076	2,128	718,744	-	-	0,006	0,070	2,162	721,005	-	-							
8	0	0	1,4	2 1+2	1	0,065	98	2	1,4	5	1	0,093	98	0,025	0,067	2,229	719,082	-	-	0,005	0,076	2,244	724,878	-	-							
9	TX47	TEF47	0,9	1 1+2	1	0,42	63	1	0,9	5	1	0,06	63	0,040	0,066	2,218	720,825	0,004	0,004	0,005	0,082	2,261	723,835	0,027	0,013							
all 9 variations	Filtertype TX	all 9 variations		arithmetic mean value	0,044	0,069	2,181	718,802	0,004	0,004	0,005	0,079	2,218	721,920	0,008	0,006	0,0004	0,0051	0,1305	3,6162	0,0078	0,0029	-	-	-	-						
		standard deviation	0,0143	0,0076	0,0965	6,1751	0,0008	0,0008	0,0004	0,0051	0,1305	3,6162	0,0078	0,0029	-	-	-	-	-	-	-	-	-	-	-	-						
		coefficient of variance	32,50	11,04	4,42	0,86	n.a.	n.a.	8,69	6,47	5,88	0,50	n.a.	n.a.	-	-	-	-	-	-	-	-	-	-	-	-						
		arithmetic mean value	0,052	0,070	2,180	720,871	0,004	0,004	0,005	0,082	2,211	722,284	0,005	0,005	0,0004	0,0042	0,1714	3,7531	0,0010	0,0011	25,37	13,70	5,69	0,78	18,31	21,24	7,98	5,10	7,75	0,52	21,46	23,44
		standard deviation	0,0133	0,0095	0,1240	5,6396	0,0007	0,0009	0,0004	0,0042	0,1714	3,7531	0,0010	0,0011	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
		coefficient of variance	25,37	13,70	5,69	0,78	18,31	21,24	7,98	5,10	7,75	0,52	21,46	23,44	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
		arithmetic mean value	0,049	0,068	2,176	718,428	0,004	0,004	0,005	0,081	2,216	721,261	0,005	0,005	0,0004	0,0045	0,1568	4,1196	0,0010	0,0011	29,04	12,89	5,21	1,04	19,59	21,11	7,65	5,60	7,08	0,57	20,83	22,20
		standard deviation	0,0143	0,0089	0,1134	7,5074	0,0008	0,0009	0,0004	0,0045	0,1568	4,1196	0,0010	0,0011	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
		coefficient of variance	29,04	12,89	5,21	1,04	19,59	21,11	7,65	5,60	7,08	0,57	20,83	22,20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
		arithmetic mean value	0,030	0,071	2,178	718,913	-	-	0,005	0,073	2,203	722,942	-	-	0,0005	0,0028	0,0410	1,9364	-	-	-	-	-	-	-	-	-	-	-	-	-	
		standard deviation	0,0054	0,0041	0,0504	0,1690	-	-	0,0005	0,0028	0,0410	1,9364	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		coefficient of variance	17,86	5,79	2,31	0,02	n.a.	n.a.	9,26	3,81	1,86	0,27	n.a.	n.a.	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
arithmetic mean value	0,033	0,070	2,192	719,551	-	-	0,005	0,076	2,222	723,239	-	-	0,0004	0,0049	0,0432	1,6361	-	-	-	-	-	-	-	-	-	-	-	-	-			
standard deviation	0,0064	0,0041	0,0452	0,9118	-	-	0,0004	0,0049	0,0432	1,6361	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
coefficient of variance	19,15	5,86	2,06	0,13	n.a.	n.a.	8,38	6,47	1,95	0,23	n.a.	n.a.	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			



Results - Engine I – Particulate Matter – Parameter variations WHTC 2




TUV NORD

Results - Engine I – Particulate Matter – Parameter variations WHSC 1

Mean values (WHSC)																										
Variation	FilterType	FilterType	FF					PF					diluted gas, PM FF [g/kWh]				raw gas, PM PF [g/kWh]									
			Gtrot [g/s]	Index Gtrot	CV/S flow (venturi comb.)	Index CV/S flow	FFV [cm/s]	Index FFV	Gtrot [g/s]	DF q	Index DF	r [%]	FFV [cm/s]	HC	CO	NOx	CO2	PMm 1.	PMm 2.	HC	CO	NOx	CO2	PMm 1.	PMm 2.	
1	TX47	TX47	0,9	1	1+2	1	0,042	63	1	1,4	5	1	0,093	98	0,028	0,069	2,490	674,513	0,006	0,006	0,002	0,059	2,605	685,575	0,006	0,006
2	1,4	2	1+2	1	0,065	98	2	1,4	5	1	0,093	98		0,022	0,062	2,433	677,920	0,004	0,004	0,003	0,071	2,484	686,566	0,003	0,003	
3	0,9	1	1+3	2	0,046	63	1	0,9	10	2	0,03	63		0,046	0,061	2,570	678,905	0,006	0,006	0,003	0,071	2,603	682,236	0,006	0,006	
4	0,9	1	1+3	2	0,046	63	1	0,9	5	1	0,06	63		0,041	0,066	2,526	682,253	0,005	0,005	0,003	0,069	2,557	682,578	0,005	0,004	
5	1,4	2	1+3	2	0,072	98	2	1,4	10	2	0,046	98		0,044	0,071	2,568	677,228	0,003	0,003	0,003	0,064	2,596	676,201	0,003	0,003	
6	TX70	TX70	0,9	1	1+2	1	0,042	26	3	0,9	5	1	0,06	26	0,021	0,057	2,372	668,543	0,009	0,009	0,002	0,058	2,516	680,554	0,008	0,008
7	1,4	2	1+2	1	0,065	98	2	1,4	5	1	0,093	98		0,023	0,070	2,479	678,732	0,006	0,002	0,002	0,062	2,505	690,532	0,026	0,002	
8	0,9	1	1+2	1	0,042	63	1	0,9	5	1	0,06	63		0,028	0,075	2,444	677,459	0,018	0,016	0,002	0,056	2,528	683,102	0,013	0,013	
9	1,4	2	1+2	1	0,065	98	2	1,4	5	1	0,093	98		0,023	0,070	2,479	678,732	0,006	0,002	0,002	0,062	2,505	690,532	0,026	0,002	
9	TX47	TEF47	0,9	1	1+2	1	0,042	63	1	0,9	5	1	0,06	63	0,029	0,069	2,524	679,882	0,005	0,004	0,011	0,063	2,590	678,234	0,009	0,001
all 9 variations														arithmetic mean value	0,031	0,067	2,489	677,270	0,007	0,006	0,003	0,064	2,554	682,842	0,009	0,005
														standard deviation	0,0092	0,0054	0,0617	3,6620	0,0041	0,0040	0,0026	0,0054	0,0441	4,1036	0,0069	0,0033
														coefficient of variance	29,48	8,13	2,48	0,54	n.a.	n.a.	79,73	8,41	1,73	0,60	n.a.	n.a.
	Variations 1 to 5													arithmetic mean value	0,036	0,066	2,517	678,164	0,005	0,005	0,003	0,067	2,569	682,631	0,005	0,004
	Variations 1 to 5													standard deviation	0,0096	0,0039	0,0514	2,5114	0,0013	0,0013	0,0003	0,0046	0,0460	3,6238	0,0012	0,0013
Variations 1 to 5													coefficient of variance	26,55	6,00	2,04	0,37	26,53	27,81	12,72	6,91	1,79	0,53	26,72	28,66	
Variations 1 to 6													arithmetic mean value	0,034	0,064	2,493	676,560	0,005	0,005	0,002	0,065	2,560	682,285	0,005	0,005	
Variations 1 to 6													standard deviation	0,0104	0,0049	0,0716	4,2559	0,0019	0,0020	0,0004	0,0054	0,0464	3,3974	0,0016	0,0017	
Variations 1 to 6													coefficient of variance	30,90	7,57	2,87	0,63	35,13	37,21	17,85	8,23	1,81	0,50	31,80	33,89	
Variations 7 to 8													arithmetic mean value	0,026	0,072	2,461	678,095	-	-	0,002	0,059	2,517	686,817	-	-	
Variations 7 to 8													standard deviation	0,0029	0,0027	0,0176	0,6364	-	-	0,0001	0,0034	0,0117	3,7151	-	-	
Variations 7 to 8													coefficient of variance	11,41	3,79	0,71	0,09	n.a.	n.a.	6,02	5,83	0,46	0,54	n.a.	n.a.	
Variations 7 to 9													arithmetic mean value	0,027	0,071	2,482	678,691	-	-	0,005	0,060	2,541	683,956	-	-	
Variations 7 to 9													standard deviation	0,0028	0,0028	0,0328	0,9896	-	-	0,0040	0,0035	0,0360	5,0569	-	-	
Variations 7 to 9													coefficient of variance	10,68	3,94	1,32	0,15	n.a.	n.a.	79,05	5,77	1,42	0,74	n.a.	n.a.	

TUV NORD

Results - Engine I – Particulate Matter – Parameter variations WHSC 2



TUV NORD

Results - Engine II – Particulate Matter - Overview 1

Variation	FF		FF				PF				diluted gas, PM FF [g/kWh]		raw gas, PM PF [g/kWh]			
	Filtertype	Filtertype	Glott [g/s]	Index Glot	Index CVS flow	f [%]	FFV [cm/s]	Index FFV	Glott [g/s]	Index DF	f [%]	FFV [cm/s]	Pl/m 1.	Pl/m 2.	Pl/m 1.	Pl/m 2.
results WHTC cold																
1	TX47	TX47	0,9	1	2+3	1	0,021	63	1	0,9	5	1	0,034	63	0,021	0,022
2			1,4	2	2+3	1	0,033	98	2	1,4	5	1	0,052	98	0,019	0,020
3			0,9	1	1+2+3	2	0,023	63	1	0,9	10	2	0,017	63	0,019	0,020
4			0,9	1	1+2+3	2	0,023	63	1	0,9	5	1	0,034	63	0,019	0,021
5			1,4	2	1+2+3	2	0,035	98	2	1,4	10	2	0,026	98	0,019	0,020
6	TX70	TX70	0,9	1	2+3	1	0,021	26	3	0,9	5	1	0,034	26	0,020	0,024
7	TEF47	TEF47	0,8	1	2+3	1	0,019	64	1	0,8	5	1	0,03	64	0,020	0,022
8			1,22	2	2+3	1	0,029	98	2	1,22	5	1	0,046	98	0,021	0,022
9	TX47	TEF47	0,9	1	2+3	1	0,021	63	1	0,8	5	1	0,03	64	0,020	0,022
results WHTC hot																
1	TX47	TX47	0,9	1	2+3	1	0,021	63	1	0,9	5	1	0,034	63	0,022	0,023
2			1,4	2	2+3	1	0,033	98	2	1,4	5	1	0,052	98	0,020	0,021
3			0,9	1	1+2+3	2	0,023	63	1	0,9	10	2	0,017	63	0,019	0,020
4			0,9	1	1+2+3	2	0,023	63	1	0,9	5	1	0,034	63	0,020	0,021
5			1,4	2	1+2+3	2	0,035	98	2	1,4	10	2	0,026	98	0,019	0,020
6	TX70	TX70	0,9	1	2+3	1	0,021	26	3	0,9	5	1	0,034	26	0,021	0,025
7	TEF47	TEF47	0,8	1	2+3	1	0,019	64	1	0,8	5	1	0,03	64	0,024	0,025
8			1,22	2	2+3	1	0,029	98	2	1,22	5	1	0,046	98	0,024	0,025
9	TX47	TEF47	0,9	1	2+3	1	0,021	63	1	0,8	5	1	0,03	64	0,023	0,024
results WHSC																
1	TX47	TX47	0,9	1	2+3	1	0,021	63	1	0,9	5	1	0,034	63	0,014	0,014
2			1,4	2	2+3	1	0,033	98	2	1,4	5	1	0,052	98	0,013	0,013
3			0,9	1	1+2+3	2	0,023	63	1	0,9	10	2	0,017	63	0,012	0,013
4			0,9	1	1+2+3	2	0,023	63	1	0,9	5	1	0,034	63	0,013	0,013
5			1,4	2	1+2+3	2	0,035	98	2	1,4	10	2	0,026	98	0,012	0,013
6	TX70	TX70	0,9	1	2+3	1	0,021	26	3	0,9	5	1	0,034	26	0,013	0,015
7	TEF47	TEF47	0,8	1	2+3	1	0,019	64	1	0,8	5	1	0,03	64	0,015	0,016
8			1,22	2	2+3	1	0,029	98	2	1,22	5	1	0,046	98	0,015	0,015
9	TX47	TEF47	0,9	1	2+3	1	0,021	63	1	0,8	5	1	0,03	64	0,012	0,013

All mean values over all parameter variations.

TUV NORD


Results - Engine II – Particulate Matter – Parameter variations WHTC 1

Mean values


Variation	FF		PF		FF		PF		diluted gas, PM FF [g/kWh]				raw gas, PM PF [g/kWh]																		
	Filtertype	Filtertype	Gtot [g/s]	Index Gtot	Gtot [g/s]	Index Gtot	Index CVS flow	Index CVS flow	HC	CO	NOx	CO2	PMm 1.	PMm 2.	HC	CO	NOx	CO2	PMm 1.	PMm 2.											
1	TX47	TX47	0,9	1	2+3	1	0,021	63	1	0,9	5	1	0,034	63	0,048	2,709	2,095	665,633	0,022	0,023	0,016	2,519	2,083	669,063	0,021	0,022					
2			1,4	2	2+3	1	0,033	98	2	1,4	5	1	0,052	98	0,045	2,665	2,244	668,670	0,020	0,021	0,017	2,587	2,314	671,437	0,021	0,018					
3			0,9	1	1+2+3	2	0,023	63	1	0,9	10	2	0,017	63	0,052	2,443	2,136	671,022	0,019	0,020	0,016	2,361	2,276	671,505	0,024	0,020					
4			0,9	1	1+2+3	2	0,023	63	1	0,9	5	1	0,034	63	0,065	2,694	2,029	671,430	0,020	0,021	0,016	2,623	2,276	675,255	0,021	0,022					
5			1,4	2	1+2+3	2	0,035	98	2	1,4	10	2	0,026	98	0,052	2,596	1,872	671,487	0,019	0,020	0,016	2,514	2,058	673,037	0,023	0,025					
6	TX70	TX70	0,9	1	2+3	1	0,021	26	3	0,9	5	1	0,034	26	0,054	2,687	2,271	664,536	0,021	0,025	0,014	2,653	2,314	666,919	0,023	0,025					
7	TEF47	TEF47	0,8	1	2+3	1	0,019	64	1	0,8	5	1	0,03	64	0,042	2,775	2,242	668,013	0,024	0,025	0,016	2,559	2,213	671,237	0,019	0,019					
8			1,22	2	2+3	1	0,029	98	2	1,22	5	1	0,046	98	0,041	2,889	2,193	666,880	0,024	0,025	0,016	2,603	2,123	667,170	0,019	0,020					
9	TX47	TEF47	0,9	1	2+3	1	0,021	63	1	0,8	5	1	0,03	64	0,032	2,939	2,294	663,613	0,023	0,024	0,014	2,990	2,512	668,858							
		all 9 variations				arithmetic mean value		0,048		2,711		2,153		667,920		0,021		0,023		0,016		2,601		2,241		670,498		0,021		0,021	
						standard deviation		0,0088		0,1398		0,1289		2,8197		0,0016		0,0018		0,0008		0,1591		0,1332		2,5852		0,0017		0,0024	
						coefficient of variance		18,31		5,16		5,99		0,42		7,69		8,04		5,45		6,12		5,94		0,39		8,05		11,34	
		Variations 1 to 5				arithmetic mean value		0,052		2,621		2,075		669,648		0,020		0,021		0,016		2,521		2,201		672,060		0,022		0,021	
						standard deviation		0,0069		0,0973		0,1233		2,2594		0,0009		0,0008		0,0005		0,0900		0,1078		2,0413		0,0011		0,0022	
						coefficient of variance		13,09		3,71		5,94		0,34		4,62		3,74		3,11		3,57		4,90		0,30		4,87		10,47	
		Variations 1 to 6				arithmetic mean value		0,053		2,632		2,108		668,796		0,020		0,022		0,016		2,543		2,220		671,203		0,022		0,022	
						standard deviation		0,0063		0,0921		0,1341		2,8079		0,0009		0,0016		0,0008		0,0957		0,1070		2,6727		0,010		0,0025	
						coefficient of variance		11,94		3,50		6,36		0,42		4,60		7,34		5,26		3,76		4,82		0,40		4,71		11,50	
		Variations 7 to 8				arithmetic mean value		0,042		2,832		2,218		667,446		0,024		0,025		0,016		2,581		2,168		669,204		0,019		0,020	
						standard deviation		0,0008		0,0569		0,0243		0,5667		0,0000		0,0001		0,0003		0,0220		0,0448		2,0335		0,0003		0,0001	
						coefficient of variance		1,94		2,01		1,09		0,08		0,16		0,25		1,83		0,85		2,07		0,30		1,72		0,64	
		Variations 7 to 9				arithmetic mean value		0,039		2,867		2,243		666,168		0,023		0,024		0,015		2,717		2,263		669,088		0,019		0,020	
						standard deviation		0,0043		0,0685		0,0410		1,8656		0,0005		0,0006		0,0008		0,1935		0,1663		1,6683		0,0003		0,0001	
						coefficient of variance		11,21		2,39		1,83		0,28		2,30		2,39		5,54		7,12		7,28		0,25		1,72		0,64	



Results - Engine II – Particulate Matter – Parameter variations WHTC 2




Results - Engine II – Particulate Matter – Parameter variations WHTC 3



Variation	FF Filtertype	PF Filtertype	Gtot [g/s]	Index Gtot	CVS flow (venturi comb)	Index CVS flow	Index CVS flow [%]	Index FFV [cm/s]	Index FFV [%]	Gtot [g/s]	DF q	Index DF	Index DF [%]	FFV [cm/s]
1	TX47	TX47	0,9	1	2+3	1	0,021	63	1	0,9	5	1	0,034	63
2			1,4	2	2+3	1	0,033	98	2	1,4	5	1	0,052	98
3			0,9	1	1+2+3	2	0,023	63	1	0,9	10	2	0,017	63
4			0,9	1	1+2+3	2	0,023	63	1	0,9	5	1	0,034	63
5			1,4	2	1+2+3	2	0,035	98	2	1,4	10	2	0,026	98
6	TX70	TX70	0,9	1	2+3	1	0,021	26	3	0,9	5	1	0,034	26
7	TEF47	TEF47	0,8	1	2+3	1	0,019	64	1	0,8	5	1	0,03	64
8			1,22	2	2+3	1	0,029	98	2	1,22	5	1	0,046	98



Results - Engine II – Particulate Matter – Parameter variations WHTC 4



Index 1-1-1-1


Var. 1 vs. Var. 7

PMm 2. FF	PMm 2. PF
0,0228	0,0227
0,0220	0,0213
0,0215	0,0211
0,0212	0,0212
0,0233	0,0221
0,0229	0,0220
0,026	0,0183
0,0244	0,0202
0,0252	0,0197
0,0242	0,0197

Variation	FF Filtertype	PF Filtertype	Gtot [g/s]	Index Gtot	CVS flow (venturi comb)	Index CVS flow	Index CVS flow [%]	Index FFV [cm/s]	Index FFV [%]	Gtot [g/s]	DF q	Index DF	Index DF [%]	FFV [cm/s]	diluted gas, PM FF [g/kWh]				raw gas, PM PF [g/kWh]								
1	TX47	TX47	0,9	1	2+3	1	0,021	63	1	0,9	5	1	0,034	63	Hc	0,048	2,709	2,095	665,633	0,022	0,023	0,016	2,519	2,083	669,063	0,021	0,022
7	TEF47	TEF47	0,8	1	2+3	1	0,019	64	1	0,8	5	1	0,03	64	Hc	0,042	2,775	2,242	668,013	0,024	0,025	0,016	2,559	2,213	671,237	0,019	0,019



Results - Engine II – Particulate Matter – Parameter variations WHTC 5



TUV NORD

Results - Engine II – Particulate Matter – Parameter variations WHSC 1


Mean values (WHSC)

Variation	FF	PF	FF	PF	diluted gas, PM FF [g/kWh]						raw gas, PM PF [g/kWh]															
Filetype	Filetype	Index Grot	Index CVs flow	Index DF	Grot [g/s]	DF q	Index DF	FFV [cm/s]	FFV [cm/s]	HC	CO	NOx	CO2	PMm 1.	PMm 2.	HC	CO	NOx	CO2	PMm 1.	PMm 2.					
1	TX47	TX47	0,9	1	2+3	1	0,021	63	1	0,9	5	1	0,034	63	0,028	0,547	1,258	629,557	0,014	0,014	0,007	0,553	1,261	631,096	0,012	0,013
2			1,4	2	2+3	1	0,033	98	2	1,4	5	1	0,052	98	0,037	0,543	1,295	633,218	0,013	0,013	0,009	0,536	1,361	630,600	0,013	0,012
3			0,9	1	1+2+3	2	0,023	63	1	0,9	10	2	0,017	63	0,044	0,534	1,259	634,522	0,012	0,013	0,007	0,524	1,056	630,048	0,012	0,013
4			0,9	1	1+2+3	2	0,023	63	1	0,9	5	1	0,034	63	0,055	0,559	1,248	635,422	0,013	0,013	0,006	0,549	1,469	632,048	0,012	0,012
5			1,4	2	1+2+3	2	0,035	98	2	1,4	10	2	0,026	98	0,062	0,539	1,217	634,110	0,012	0,013	0,006	0,537	1,233	630,919	0,013	0,014
6	TX70	TX70	0,9	1	2+3	1	0,021	26	3	0,9	5	1	0,034	26	0,030	0,547	1,282	629,929	0,013	0,015	0,005	0,542	1,304	629,990	0,013	0,014
7	TEF47	TEF47	0,8	1	2+3	1	0,019	64	1	0,8	5	1	0,03	64	0,023	0,564	1,330	632,941	0,015	0,016	0,007	0,538	1,274	631,236	0,012	0,012
8			1,22	2	2+3	1	0,029	98	2	1,22	5	1	0,046	98	0,027	0,598	1,373	632,195	0,015	0,015	0,007	0,545	1,285	626,579	0,012	0,012
9	TX47	TEF47	0,9	1	2+3	1	0,021	63	1	0,8	5	1	0,03	64	0,019	0,532	1,427	628,866	0,012	0,013	0,006	0,519	1,480	619,229		

Variations	FF	PF	all 9 variations					
			arithmetic mean value	standard deviation	coefficient of variance	arithmetic mean value	standard deviation	coefficient of variance
Variations 1 to 5	FF	PF	0,045	0,545	1,255	633,366	0,013	0,013
			0,0124	0,0087	0,0248	2,0320	0,0005	0,0005
			27,33	1,59	1,97	0,32	4,15	3,82
Variations 1 to 6	FF	PF	0,043	0,545	1,260	632,793	0,013	0,014
			0,0126	0,0080	0,0247	2,2541	0,0005	0,0008
			29,44	1,46	1,96	0,36	3,88	5,81
Variations 7 to 8	FF	PF	0,025	0,581	1,352	632,568	0,015	0,015
			0,0019	0,0171	0,0216	0,3731	0,0000	0,0002
			7,54	2,94	1,59	0,06	0,17	1,47
Variations 7 to 9	FF	PF	0,023	0,564	1,377	631,334	0,014	0,015
			0,0033	0,0272	0,0396	1,7713	0,0013	0,0012
			14,08	4,81	2,88	0,28	9,02	8,15

TUV NORD

Results - Engine II – Particulate Matter – Parameter variations WHSC 2




Results - Engine II – Particulate Matter – Parameter variations WHSC 3

Index 1-1-1-1

Var. 1 vs Var. 7

PMm 2. FPMm 2. PF

0,0136	0,0122
0,0141	0,0126
0,0150	0,0131
0,0148	0,0133
0,0157	0,0120
0,0154	0,0126




Results - Engine II – Particulate Matter – Parameter variations WHSC 4

Index 2-1-2-1

Var. 2 vs. Var. 8

PMm 2.	FFPMm 2.	PF
0,0130	0,0128	
0,0129	0,0129	
0,0131	0,0120	
0,0130	0,0128	
0,0132	0,0120	
0,0131	0,0118	
0,0151	0,0124	
0,0151	0,0124	



Particulate Matter – Conclusions

The partial flow particulate matter measurement according to ISO 16183 respectively GTR No. 4 showed again good to very good agreement in comparison to the CVS procedure.

Lowest variability was observed with low dilution ratios and high filter face velocities.

Filter diameter influence was not observed. Teflo filter in 70mm with bonded ring not commercially available.

Teflo filter results slightly higher with FF than with PF; statistical significant when results from engine 1 are available. With PF system no influence of the filter material (Teflo vs. TX) was observed.




TX Filter vs. Teflo Filter

- Both filter materials came from same supplier.
- Teflo filter is hard to handle.
 - => e.g. sticks to filter holder form PF system
- Teflo weighing results on engine I not reliable.
 - => less filter weight / much higher filter weight
(electrostatic charge not completely removed)
- Teflo filter showed further remarkable details such as:



Teflo Filter - I



Several filters show small perforation at the edge between filter and ring as delivered.



Teflo Filter – II, Discharging essential



§1065.190 PM-stabilization and weighing environments for gravimetric analysis.

(6) We recommend that you neutralize PM sample media (e.g. filter) to within ± 2.0 V of neutral. Measure static voltages as follows:

- (i) Measure static voltage of PM sample media (e.g. filter) according to the electrostatic voltmeter manufacturer's instructions.
- (ii) Measure static voltage of PM sample media (e.g. filter) while the media is at least 15 cm away from any grounded surfaces to avoid mirror image charge interference.



Ongoing Activities

- Engine I additional tests on Teflo to be evaluated
- Statistics (F-Test and t-test) to be applied
- Final presentation scheduled for 27th WHDC meeting

TÜV Nord Mobilität – IFM
Motoren / Nutzfahrzeuge
Essen

Ischulte@tuev-nord.de

