



**Economic and Social
Council**

Distr.
GENERAL

ECE/EB.AIR/WG.5/2009/18
16 June 2009

Original: ENGLISH

ECONOMIC COMMISSION FOR EUROPE

**EXECUTIVE BODY FOR THE CONVENTION ON LONG-RANGE
TRANSBOUNDARY AIR POLLUTION**

Working Group on Strategies and Review

Forty-fifth session

Geneva, 31 August–4 September 2009

Item 4 of the provisional agenda

OPTIONS FOR REVISING THE GOTHENBURG PROTOCOL

DRAFT REVISED TECHNICAL ANNEX V

Note by the secretariat

Summary

At its forty-fourth session in April 2009, the Working Group on Strategies and Review welcomed the work carried out by the Expert Group on Techno-economic issues on updating the technical annexes IV, V, VI and VIII and the guidance documents and on elaborating new annexes on volatile organic compounds (VOC) in products and on particulate matter (PM). It requested the secretariat to submit them as official documents for negotiation at the forty-fifth session of the Working Group (ECE/EB.AIR/WG.5/96, para. 42 (d–e)). This note presents a draft revised technical annex V as suggested by the Expert Group on Techno-economic Issues.

Annex V

LIMIT VALUES FOR EMISSIONS OF NITROGEN OXIDES FROM STATIONARY SOURCES

1. Section A applies to Parties other than Canada and the United States of America, section B applies to Canada and section C applies to the United States of America.

A. Parties other than Canada and the United States of America

2. For the purpose of section A, limit value means the quantity of a gaseous substance contained in the waste gases from an installation that is not to be exceeded. Unless otherwise specified, it shall be calculated in terms of mass of pollutant per volume of the waste gases (expressed as mg/m³), assuming standard conditions for temperature and pressure for dry gas (volume at 273.15 K, 101.3 kPa). With regard to the oxygen content of exhaust gas, the values given in the tables below for each source category shall apply. Dilution for the purpose of lowering concentrations of pollutants in waste gases is not permitted. Limit values generally address NO together with NO₂, commonly named NOx, expressed as NO₂. Start-up, shutdown and maintenance of equipment are excluded.

3. Emissions shall be monitored^a in all cases. Compliance with limit values shall be verified. The methods of verification can include continuous or discontinuous measurements, type approval, or any other technically sound method. In case of continuous measurements, compliance with the emission standards is achieved if the validated [daily/monthly]^b emission average does not exceed the limit values. In case of discontinuous measurements or other appropriate determination procedures, compliance with the emission standards is achieved if the mean value based on an appropriate number of measurements under representative conditions does not exceed the value of the emission standard. The inaccuracy of the continuous and discontinuous measurement methods may be taken into account for verification purposes.

4. Sampling and analysis of relevant polluting substances and measurements of process parameters, as well as the quality assurance of automated measuring systems and the reference measurement methods to calibrate those systems, shall be carried out in accordance with CEN

^a Monitoring is to be understood as an overall activity, comprising measuring or calculating of emissions, mass balancing, etc. It can be carried out continuously or discontinuously.

^b One option is to define the ELVs as daily averages, another option is to define the ELVs as monthly averages; shorter averaging periods can be considered as being more strict.

standards. If CEN standards are not available, ISO standards, national or international standards which will ensure the provision of data of an equivalent scientific quality shall apply.

5. Special provisions for combustion plants with a rated thermal input exceeding 50 MWth and for combustion plants when combined to a common stack with a total rated input exceeding 50 MWth:

5.1 The competent authority may grant derogation from the obligation to comply with the emission limit values provided for in paragraph 5 in the following cases:

[a) for combustion plants using [only/mainly] gaseous fuel who have to resort exceptionally to the use of other fuels because of a sudden interruption in the supply of gas and for this reason would need to be equipped with a waste gas purification facility]

[b) for combustion plants not operated more than XXX operating hours, starting from DATE and ending no later than DATE]

[c) for existing combustion plants using solid or liquid fuels not operated more than 1500 operating hours per year as a rolling average over a period of five years; instead following emission limit values apply:

for solid fuels: [option 1 and 2 = 450 mg/Nm³; option 3 = 600 mg/Nm³]¹

for liquid fuels: [option 1, 2 and 3 = 450 mg/Nm³]¹]

5.2 Where a combustion plant is extended by at least 50MW, the emission limit value specified in paragraph 7 for new installations shall apply to the extensional part and to the part of the plant affected by the change.

5.3 Parties shall ensure that provisions are made in the permits for procedures relating to malfunction or breakdown of the abatement equipment.

5.4 In the case of a multi-fuel firing combustion plant involving the simultaneous use of two or more fuels, the competent authority shall provide rules for setting the emission limit values

6. Mineral oil refineries complying with the overall NO_X limit value set in table 1 may be exempted from compliance with the individual NO_X limit values provided in this annex. Following alternative bubble NO_X limit value may be used, referring to the sum of the emissions from all combustion plants and process installations expressed as an average concentration and at a reference oxygen content of [3%]:

Table 1. Suggested options for limit values for NO_x emissions released from refineries using the bubble concept

	Suggested ELV for NO _x [mg/Nm ³]		
	Option 1 ^{1/}	Option 2 ^{1/}	Option 3 ^{1/}
	Mineral oil refinery	150	300

Oxygen reference: dry basis, 3% for combustion, 15 % for gas turbines

7. Combustion plants (boilers and process heaters) with a rated thermal input exceeding 50 MWth or combustion plants when combined to a common stack with a total rated input exceeding 50 MWth^c:

Table 2. Suggested options for limit values for NO_x emissions released from boilers [and process heaters]^{a/}

Fuel type	Thermal input [MWth]	Suggested ELV for NO _x [mg/Nm ³] ^{b/}		
		Option 1 ^{1/}	Option 2 ^{1/}	Option 3 ^{1/}
Solid fuels	50-100	New plants: 250 (coal, lignite) 200 (biomass, peat)	New plants: 300 (coal, lignite) (pulverised lignite: 450) 250 (biomass, peat)	New plants: 400 (coal, lignite) (pulverised lignite 450) 400 (biomass, peat)
		Existing plants: 250 (coal, lignite) 250 (biomass, peat)	Existing plants: 300 (coal, lignite) (pulverised lignite: 450) 300 (biomass, peat)	Existing plants: 600 (coal, lignite) 600 (biomass, peat)
	100-300	New plants: 150 (coal, lignite) 150 (biomass, peat)	New plants: 200 (coal, lignite) 200 (biomass, peat)	New plants: 200 (coal, lignite) 300 (biomass, peat)
		Existing plants: 200 (coal, lignite) 200 (biomass, peat)	Existing plants: 200 (coal, lignite) 250 (biomass, peat)	Existing plants: 600 (coal, lignite) 600 (biomass, peat)
	>300	New plants: 100 (coal, lignite) 100 (biomass, peat)	New plants: 150 (coal, lignite) 150 (biomass, peat)	New plants: 200 (coal, lignite) 200 (biomass, peat)
		Existing plants: 100 (coal, lignite) 100 (biomass, peat)	Existing plants: 200 (coal, lignite) 200 (biomass, peat)	Existing plants: 200 (coal, lignite) 200 (biomass, peat)
Liquid fuels	50-100	New plants: 250	New plants: 300	New plants: 400

^c Individual combustion plants below 15 MWth shall not be considered to calculate the total rated input.

Fuel type	Thermal input [MWth]	Suggested ELV for NO _x [mg/Nm ³] ^{b/}		
		Option 1 ^{1/}	Option 2 ^{1/}	Option 3 ^{1/}
		Existing plants: 300	Existing plants: 450	Existing plants: 450
Natural gas	100-300	New plants: 100	New plants: 150	New plants: 200
		Existing plants: 150	Existing plants: 200	Existing plants: 450
	>300	New plants: 80	New plants: 100	New plants: 200
		Existing plants: 100	Existing plants: 150	Existing plants: 400
Other gaseous fuels ^{c/}	50-300	New plants: 80	New plants: 100	New plants: 150
		Existing plants: 80	Existing plants: 100	Existing plants: 300
	>300	New plants: 60	New plants: 100	New plants: 100
		Existing plants: 80	Existing plants: 100	Existing plants: 200
	>50	New plants: 200	New plants: 200	New plants: 200
		Existing plants: 300	Existing plants: 300	Existing plants: 300

a/ In particular, the limit values shall not apply to:

- Plant where the combustion process is an integrated part of a specific production, for example the coke oven used in the Iron and Steel industry and glass and ceramics production plants;
- Plant in which the products of combustion are used for direct heating, drying, or any other treatment of objects or materials;
- Post-combustion plants designed to purify the waste gases by combustion which are not operated as independent combustion plants;
- Facilities for the regeneration of catalytic cracking catalysts;
- Facilities for the conversion of hydrogen sulphide into sulphur;
- Reactors used in the chemical industry;
- Coke battery furnaces;
- Cowpers;
- [Recovery boilers for black liquor within installations for the production of pulp]
- Waste incinerators; and
- Plant powered by diesel, petrol or gas engines or by combustion turbines, irrespective of the fuel used.

b/ These values do not apply to combustion plants running less than 500 hours a year. The O₂ reference content is 6% for solid fuels and 3% for others.

c/ including refinery gases, coke oven gases, blast furnace gases, BOF gases

8. Onshore combustion turbines with a rated thermal input exceeding 50MWth: the NO_x limit values expressed in mg/Nm³ (with an O₂ content of 15%) are to be applied to a single turbine. The limit values in table 2 apply only above 70% load.

Table 3. Suggested options for limit values for NO_x emissions released from onshore combustion turbines (including CCGT)

Fuel type	Thermal input [MWth]	Suggested ELV for NO_x [mg/Nm³]^{a/}		
		Option 1^{1/}	Option 2^{1/}	Option 3^{1/}
Liquid fuels (light and medium distillates)	>50	New plants: 50	New plants: 100	New plants: 120
		Existing plants: 90	Existing plants: 120	Existing plants: 120
Natural gas ^{b/}	>50	New plants: 50	New plants: 50	New plants: 50
		Existing plants: 50	Existing plants: 90	Existing plants: 120
Other gases ^{c/}		New plants: 50	New plants: 50	New plants: 50
		Existing plants: 75	Existing plants: 120	Existing plants: 120

a/ O₂ content of 15%. Gas turbines for emergency use that operate less than 500 hours per year are not covered. The ELVs apply only above 70% load

b/ Natural gas is naturally occurring methane with not more than 20% (by volume) of inert and other constituents.

c/ [e.g. for supplementary firing with other gases]

9. Cement production:

Table 4. Suggested options for limit values for NO_x emissions released from cement production^{a/}

	Suggested ELV for NO_x [mg/Nm³]		
	Option 1^{1/}	Option 2^{1/}	Option 3^{1/}
New installations			
- preheater kilns	300	400	500
- other kilns	400	800	800
Existing installations	400	800	1200

a/ Installations for the production of cement clinker in rotary kilns with a capacity >500 Mg/day or in other furnaces with a capacity >50 Mg/day. The O₂ reference content is 10%.

10. Stationary engines

The emission limit values in table below are proposed in 15 % reference oxygen content because this corresponds to the actual operational conditions of stationary engines.

The limit value of, for instance:

- 190 mg NO_x/Nm³ in 15 % O₂ corresponds to the limit of 500 mg NO_x/Nm³ in 5 % O₂,
- 95 mg NO_x/Nm³ in 15 % O₂ corresponds to 250 mg NO_x/Nm³ in 5 % O₂ and
- 225 mg NO_x/Nm³ in 15 % O₂ corresponds to 600 mg NO_x/Nm³ in 5 % O₂.

Table 5. Suggested options for limit values for NO_x emissions released from new stationary engines

ENGINE TYPE, POWER, FUEL SPECIFICATION	ELV 1 (a) (b) (c) [mg/Nm ³]	ELV 2(a) (b) (c) [mg/Nm ³]	ELV 3(a) [mg/Nm ³]
GAS ENGINES > 1 MW_{th} Spark ignited (=Otto) engines all gaseous fuels	35	95	190
DUAL FUEL ENGINES > 1 MW_{th} In gas mode (all gaseous fuels) In liquid mode (all liquid fuels)	35 (e)	190(e)	380(e)
1-20 MW	225	750	[1850] [2000]
>20 MW	225(e)	450	[1850] [2000]
DIESEL ENGINES > 5 MW_{th} (compression ignition)			
Slow (< 300 rpm)/ Medium (300-1200 rpm)/ speed			
5-20 MW	225	[450] [750]	[1300] (d)
HFO and bio-oils	150	190	[1600]
LFO and NG			[1300] (d)
>20 MW	190	[225] [450]	[1600]
HFO and bio-oils	150	190	[750] [1850]
LFO and NG		190	[750] [1850]
High speed (>1200 rpm)	[130] [150]		[750] [900]

The oxygen reference content is 15%

- (a) These values do not apply to engines running less than 500 hours a year.
- (b) Where SCR cannot currently be applied [for certain geographical areas, like remote islands] or the unavailability of good fuel or raw material quality not guaranteed, a transition period of [x] yrs can be granted. During this transition period the upper value of ELV3 can be applied.
- (c) A flexibility option for engines running between 500 to 1500 operational hours per year is to apply [the upper values of ELV3] [achievable with primary measures].

(d) Limit of primary measures under development (Currently only first laboratory tests done on some engine type.)

(e) A derogation from the obligation to comply with the emission limit values can be granted to combustion plants using gaseous fuel which have to resort exceptionally to the use of other fuels because of a sudden interruption in the supply of gas and for this reason would need to be equipped with a waste gas purification facility. The exception time period shall not exceed 10 days except where there is an overriding need to maintain energy supplies.

[Since engines running with higher energy efficiency consume less fuel and emit therefore less CO₂ and since higher efficiency of the engines can lead to higher temperatures and therefore to higher NO_x concentrations in the flue gases, a NO_x bonus using the formula [ELV x actual efficiency / reference efficiency] could be justified^d.]

11. Production and processing of metals:

Table 6. Suggested options for limit values for NO_x emissions released from primary iron and steel^{a/} production

Plant type	Suggested ELV for NO_x [mg/Nm³]^{b/}		
	Option 1^{1/}	Option 2^{1/}	Option 3^{1/}
Sinter plants: New installation	[... ^{c/}]	400	400
Sinter plants: Existing installation	[... ^{c/}]	400	400

a/ Production and processing of metals: metal ore roasting or sintering installations, installations for the production of pig iron or steel (primary or secondary fusion) including continuous casting with a capacity exceeding 2.5 Mg/hour, installations for the processing of ferrous metals (hot rolling mills > 20 Mg/hour of crude steel).

b/ As an exemption to paragraph 3, these ELVs should be considered as averaged over a substantial period of time

c/ SCR is considered as part of the BAT in the European Reference document but no BAT-AEL is reported.

12. Nitric acid production:

^d See e.g. U K “Environmental Protection Act 1990, part 1 (1995 revision), PG 1/5 (95): Secretary of state’s Guidance-compression Ignition Engines, 20 – 50 MW Net rated Thermal Input” (prescribes efficiency correction from 40 %).

Table 7. Suggested options for limit values for NO_x emissions from nitric acid production excluding acid concentration units

Type of installations	Suggested ELV for NO _x [mg/Nm ³]		
	Option 1 ^{1/}	Option 2 ^{1/}	Option 3 ^{1/}
New installations	40	154	200
Existing installations	100	185	200

B. Canada^{2/}

13. Limit values for controlling emissions of nitrogen oxides (NOx) from new stationary sources in the following stationary source categories will be determined on the basis of available information on control technology and levels including limit values applied in other countries and the following documents:

- (a) Canadian Council of Ministers of the Environment (CCME). National Emission Guidelines for Stationary Combustion Turbines. December 1992. PN1072;
- (b) Canada Gazette, Part I. Department of the Environment. Thermal Power Generation Emissions - National Guidelines for New Stationary Sources. May 15, 1993. pp. 1633-1638; and
- (c) CME. National Emission Guidelines for Cement Kilns. March 1998. PN1284.

C. United States of America^{2/}

14. Limit values for controlling emissions of NOx from new stationary sources in the following stationary source categories are specified in the following documents:

- (a) Coal-fired Utility Units - 40 Code of Federal Regulations (C.F.R.) Part 76;
- (b) Electric Utility Steam Generating Units - 40 C.F.R. Part 60, Subpart D, and Subpart Da;
- (c) Industrial-Commercial-Institutional Steam Generating Units - 40 C.F.R. Part 60, Subpart Db;
- (d) Nitric Acid Plants - 40 C.F.R. Part 60, Subpart G;
- (e) Stationary Gas Turbines - 40 C.F.R. Part 60, Subpart GG;
- (f) Municipal Waste Combustors - 40 C.F.R. Part 60, Subpart Ea, and Subpart Eb; and
- (g) Hospital/Medical/Infectious Waste Incinerators - 40 C.F.R. Part 60, Subpart Ec.

Note

1/ The definitions of option 1, option 2 and option 3 are as follows. These options were designed to leave maximum flexibility for discussion by the Working Group on Strategies and Review.

Options for ELVs are as follows:

- Option 1: ELV1 is a demanding but technically feasible option with the objective of achieving a high level of reduction. The ELV1 is based on a value between the lower and upper BAT AEL, (where it is available),
- Option 2: ELV2, while technically demanding, pays greater attention to the costs of the measures for achieving reduction. The ELV2 is a value based on the upper BAT AEL (where it is available),
- Option 3: ELV 3 represents current [good] practices based on the legislation of a number of Parties to the Convention.

2/ Up to now, no information has been provided by North America, therefore part B and C of the annex have not been modified yet.

APPENDIX: JUSTIFICATIONS FOR THE OPTIONS FOR “STATIONARY ENGINES”**TABLE 8. PROPOSED ELVs**

ENGINE TYPE, POWER, FUEL SPECIFICATION	ELV 1 [mg/Nm³]	ELV 2 [mg/Nm³]	ELV 3 [mg/Nm³]
GAS ENGINES > 1 MW_{th} Spark ignited (=Otto) engines all gaseous fuels	35 – SCR with high efficiency	95 - enhanced lean burn	190 - lean burn
DUAL FUEL ENGINES > 1 MW_{th} In gas mode (all gaseous fuels) In liquid mode (all liquid fuels)			
1-20 MW	35 - SCR with high efficiency 225 - SCR with high efficiency	190 - enhanced lean burn 750 - SCR with moderate efficiency	380 - lean burn [1850] [2000] with primary measures depending on fuel and engine design [1850] [2000] – with primary measures depending on fuel and engine design
>20 MW	225 - SCR with high efficiency	450 – SCR with moderate efficiency	
DIESEL ENGINES > 5 MW_{th} (compression ignition)			
<i>Slow (< 300 rpm) / Medium (300-1200 rpm)/ speed</i>			
5-20 MW	225 SCR with high efficiency	[450] [750] SCR with moderate efficiency	[1300] (d) [1600] primary measures
HFO and bio-oils			
LFO and NG	150 SCR with high efficiency	190 SCR with high efficiency	[1300] (d) [1600] primary measures
>20 MW	190 SCR with high efficiency	[225] SCR with high efficiency [450] SCR with moderate efficiency	[750] SCR [1850] primary measures
HFO and bio-oils			
LFO and NG	150 SCR with high efficiency	190 SCR with high efficiency	[750] SCR [1850] primary measures
<i>High speed (>1200 rpm)</i>	[130] [150] SCR with high efficiency	190 SCR with high efficiency	[750] [900] primary measures

GAS ENGINES

SG-type engine

ELV1

The emission limit value of 35 mg NO_x/Nm³ is based on the best available technical measures (cost not in main focus) to reduce NO_x emissions from new stationary engines. The new emission limit for the spark ignition engine requires the use of SCR and an availability of a fuel of an adequate quality. The driving force for application of SCR is often the need to improve local air quality especially in severely degraded air-sheds, to comply with the high reduction targets of NO_x emissions. In application of SCR on gas engines caution should be taken especially on part loads in order not to overheat (“destroy”) the SCR.

ELV2

The proposed NO_x ELV of 95 mg /Nm³ for SG-type gas engines is consistent with the use of enhanced lean burn principle (primary measures) and is a part of BAT. For a spark ignition engine (SG) enhanced lean burn can cause an increase in fuel consumption (up to 3% in fuel consumption and corresponding CO₂ emission), and unburned gaseous emissions such as CO emissions and a lower flue gas temperature (detrimental for CHP applications) compared to “normal” lean burn. Certain gas (e.g. some bio gases) compositions set also limitations on the achievable NO_x-level to 95 mg NO_x/Nm³ (15 % O₂) but possible fluctuations of gas composition and contaminations may have to be considered when defining emission limit values if achievable or not.

ELV3

The proposed ELV of 190 mg NO_x/Nm³ is consistent with the use of the lean burn principle (corresponding with primary measures), also representing BAT. This level can be achieved by standard lean burn engines. The proposed ELV of 190 mg/Nm³ can also be achieved by rich burn engines equipped with a 3-way catalyst (NSCR).

DUAL FUEL ENGINES (DF)

Dual fuel engines in gas mode

ELV1

The emission limit value of 35 mg NO_x/Nm³ is based on the best available technical measures (cost not in main focus) to reduce NO_x emissions from new dual fuel engines in gas mode. The proposed emission limit value requires the use of SCR and an availability of a fuel of an adequate quality. The driving force for application of SCR is often the need to improve local air quality especially in severely degraded air-sheds to comply with the high reduction targets of NO_x emissions. In application of SCR on DF-type of engines in gas mode caution should be taken especially on part loads in order not to overheat (“destroy”) the SCR.

ELV2

The emission limit value of 190 mg NO_x/Nm³ for dual fuel (DF) gas engines in gas mode, can be complied with the enhanced lean-burn principle (primary measures) of the engine, representing BAT.

ELV 3

The emission limit value of 380 mg NO_x/Nm³ for dual fuel (DF) gas engines in gas mode, can be complied with the lean-burn principle (primary measures) of the engine with optimum fuel consumption and lowest unburned gaseous emissions of CO, etc., which is according to the IPPC principle and have been considered to represent also BAT for DF engines in gas mode. The limit value of 380 mg NO_x/Nm³ (15 % O₂) for DF engines in gas mode has following additional advantages (besides those listed above) compared to the limit value of 190 mg NO_x/Nm³: ... higher flue gas temperature, easier to tune at site (DF engine is sensitive to differences in gas compositions).

Dual fuel engines in liquid mode**ELV1**

A dual fuel engine has been developed for countries where natural gas is available. It is optimized for gaseous operation (has a lower compression ratio in comparison to a modern diesel engine) and has therefore in the liquid mode/back-up mode, higher NO_x emissions compared to a modern diesel engine. The dual fuel engines are usually only operated by liquid fuels in special cases like in the interruption of gas supply. They can however also be operated for a longer time in liquid mode (e.g. at a power plant when there is immediate power need before a gas terminal or a gas pipe line is ready). The proposed emission limit value of 225 mg NO_x/Nm³ for long time main operation use of liquid fuels are used as the main fuel for a longer period of time, can be achieved by the use of a SCR (cost not in main focus) with an efficiency of near 90 %.

ELV2

The emission limit values of 750 mg NO_x/Nm³ for the smaller DF engines in liquid mode (< 20 MW_{th}) can be achieved by the use of a SCR with an efficiency of 60 to 65 %.

The emission limit values of 450 mg NO_x/Nm³ for the larger DF engines in liquid mode (> 20 MW_{th}) can be achieved by the use of a SCR with an efficiency of 75 to 80 %.

ELV 3

The emission limit values of 1850 and 2000 mg NO_x/Nm³ for DF engines in liquid mode are achievable with primary measures like an optimized low-NO_x engine depending on fuel and engine design. Application of the limit value of 1850 mg NO_x/Nm³ means higher fuel consumption and loss of efficiency compared to the ELV of 2000 mg NO_x/Nm³.

DIESEL ENGINES

For diesel engines the ELVs are proposed by taking into account the capacity of the engine.

ELV1

Slow (< 300 rpm) / Medium (300-1200 rpm)/ speed diesel engines

When using heavy oil and bio-oils the emission limit value of 225 mg NO_x/Nm³ for diesel engines from 5 to 20 MW and 190 mg NO_x/Nm³ for diesel engines of more than 20 MW can only be achieved by the use of a SCR ((cost not in main focus) with an efficiency of respectively about 85 % and 90% depending on the engine type.

When using light fuels oil and natural gas the emission limit value of 150 mg NO_x/Nm³ can only be achieved by the use of a SCR (cost not in main focus) with an efficiency of more than 90%.

High speed (>1200 rpm) diesel engines

The emission limit value of 130 and 150 mg NO_x/Nm³ for high speed diesel engines can only be achieved by the use of a SCR (cost not in main focus) with an efficiency of respectively more than 85% and more than 80 %.

ELV2

Slow (< 300 rpm) / Medium (300-1200 rpm)/ speed diesel engines

5-20 MW

For the smaller engine capacities (5 - 20 MW) the ELVs of 450 mg/Nm³ or 750 mg/Nm³ when heavy fuel oil and bio-oils are used, assume the application of a SCR with an efficiency of respectively more than 70 % and more than 50 %. When light fuel oil and natural gas is used, the ELV of 190 mg/Nm³ can only be achieved with a SCR having a reduction efficiency of 85 to 90 %.

The NO_x value of 750 mg/Nm³ (15 % O₂) is in line with emission ruling in several EU states (e.g. Italy, France), this value will give a better economic performance of the SCR. Major part of the operational cost of the SCR is due to the reagent consumption, i.e. a lower NOx limit means also a higher reagent consumption need and thus a higher cost.

> 20 MW

For the larger engine capacities (> 20 MW) when heavy fuel oil and bio-oils are used, the ELV of 225 mg NO_x/Nm³ assumes the application of a SCR with a reduction efficiency of more than 85 % and the ELV of 450 mg NO_x/Nm³ can be achieved with a SCR with a lower reduction efficiency of more than 75 % (and reagent need and thus lower operational cost). When light fuel oil and natural gas is used, the ELV of 190 mg NO_x/Nm³ can only be achieved with a SRC having a reduction efficiency of 90 %.

High speed (>1200 rpm) diesel engines

The emission limit value of 190 mg NO_x/Nm³ for high speed diesel engines can only be achieved by the use of a SCR with a moderate reduction efficiency of near 80 %.

ELV3

Slow (< 300 rpm) / Medium (300-1200 rpm)/ speed diesel engines

5-20 MW

When using heavy fuel oil, bio-oils, light fuel oil or natural gas the emission limit value of 1 300 and 1600 mg NO_x/Nm³ for diesel engines from 5 MW to 20 MW can be reached by using primary measures like an optimized low-NO_x engine.

The NO_x level of 1300 mg/Nm³ (an efficient “dry” primary method is needed for the future international markets) is an option that allows the use of primary measures, such as “wet methods” or advanced Miller concept. Diesel manufacturers (EUROMOT) have in some preliminary laboratory tests seen that by introducing a new extreme Miller concept that NO_x-levels of 1300 mg/Nm³ with a lower fuel consumption (and as a consequence lower CO₂ emissions) could be achieved but a lot of engine testing and development work still to be done in order to get this to a commercial level.

> 20 MW

When using heavy fuel oil, bio-oils, light fuel oil or natural gas the emission limit value of 750 mg NO_x/Nm³ for diesel engines of more than 20 MW can only be complied with the use of a SCR with a reduction efficiency of 60 %, and the ELV of 1850 mg NO_x/Nm³ can be reached by using primary measures like an optimized low-NO_x engine.

High speed (>1200 rpm) diesel engines

The high-speed engines can comply with emission limit values of 750 and 900 mg NO_x/Nm³ by primary measures where the engine is optimized. The value of 900 mg NO_x/Nm³ (15 % O₂) corresponds to current US Tier 2 requirements. Engineering work would be necessary to achieve an emission limit value of 750 mg NO_x/Nm³ without secondary measures, which will result in an increase of specific fuel consumption.

The distinction between small and large engine plants is justified since the smaller engines are often installed in sectors which are economically less viable compared to the larger engines installed by the large electricity producers. The cost of SCR with lower efficiencies is less, since the cost of a SCR is mainly determined by the cost of NH₃ or urea (operational cost). To avoid odour emissions of NH₃ the operation of a SCR needs good control and maintenance, which is more easily to be enforced on the larger engine plants.

The application of SCR means for diesel engines that fuels with good quality (like fuels with low sulphur content) are needed and some restrictions to use have to be taken into account. The costs for application of SCR are plant specific and operational and maintenance costs are dependent on

the NO_x reduction rate. The impact of applying NO_x emission limit values on fuel consumption quality needs to be considered taking into account the currently rising fuel prices.

The proposed exemptions for new diesel engines operating in isolated areas can be justified because exemptions are meant to be used mainly on islands or remote areas where

- 1) there is no possibility so far to replace diesel engines with gas engines,
- 2) the application of SCR in diesel engines using heavy fuel oil is not technically or economically feasible or
- 3) the application is not feasible due to the peak-load operation and varying loads of engines or other infrastructural reasons (lack of needed reagents, etc).

The exemption is allowed for transitional period of [x] years or until the moment when certain conditions are met to apply SCR, for instance, when low-sulphur fuels and a good infrastructure for SCR, or natural gas are available.

It is expected that more grid stability power plants will be needed due to large increase in renewable energy production (e.g. wind and solar power). These “grid stabilization” plants are expected to operate up to 1500 hr/year, a grid stabilization plant will typically have frequent start-up/shut-down periods and operate on varying loads (therefore SCR is not recommended, see BREF document for more info). Therefore leaner NO_x-emission limits should be justified for these plants operating typically 500-1500 h/year.