

**Economic Commission for Europe**

**Inland Transport Committee**

**Working Party on the Transport of Dangerous Goods**

**Joint Meeting of Experts on the Regulations annexed to the  
European Agreement concerning the International Carriage  
of Dangerous Goods by Inland Waterways (ADN)  
(ADN Safety Committee)**

**Thirty-second session**

Geneva, 22-26 January 2018

Item 4 (b) of the provisional agenda

**Implementation of the European Agreement concerning the International  
Carriage of Dangerous Goods by Inland Waterways (ADN):  
special authorizations, derogations and equivalents**

---

19 January 2018

English

**Request for a derogation for tank vessel "Marconi"**

**Transmitted by the Government of Serbia**

**Addendum**

Република Србија  
Потпредседница Владе  
Министарство  
грађевинарства, саобраћаја  
и инфраструктуре  
Немањина 22-26  
11000 Београд



Republic of Serbia  
Deputy Prime Minister  
Ministry of construction,  
transport and infrastructure  
22-26, Nemanjina Str.  
11000 Belgrade  
Serbia

---

Tel: +381 (0)11 3617 632 \* Fax: +381 (0)11 3621 526 \* <http://www.mgsi.gov.rs/>

---

Courtesy Translation  
Belgrade, January 19, 2018

**Addendum to INF.22 -Decision of the ADN Administrative Committee relating to the use of a dry aerosol generating fire extinguisher system (Fire Pro) on the tank vessel "Marconi"**

Derogation No. XX/2018 of XX January 2018

The Competent authority of Serbia is authorized to issue an addition to the certificate of approval of the tank vessel "Marconi" for the use of a dry aerosol generating fire extinguisher system (Fire Pro).

Pursuant to paragraph 1.5.3.2 of the Regulations annexed to ADN, the above-mentioned vessel may deviate until 31 December 2018 from the requirement of paragraph 9.3.1.40.2.1, Extinguishing agent: The extinguishing agent is not listed in the paragraph. The vessel is equipped with a permanently fixed fire extinguisher agent of the dry aerosol generating fire extinguishing system (Fire Pro).

The Administrative Committee decides that the use of this dry aerosol generating fire extinguisher is sufficiently safe if the conditions set by the Central Commission for the Navigation of the Rhine (CCNR)\* are met at all times.

The following condition shall also apply:

1. All data related to use of the dry aerosol generating fire extinguisher system (Fire Pro) shall be collected by the carrier. The data shall be sent to the competent authority on request.
2. After use of the permanently fixed fire extinguisher agent, an evaluation report shall be sent to UNECE secretariat for information of the Administrative Committee, including the operational data and the inspection report by the classification society which classed the vessel.

**Economic Commission for Europe  
Inland Transport Committee  
Working Party on the Transport of Dangerous Goods  
Joint Meeting of Experts on the Regulations annexed to the  
European Agreement concerning the International Carriage  
of Dangerous Goods by Inland Waterways (ADN)  
(ADN Safety Committee)**

---

\* Refer to informal document INF.3 submitted at the 28th session of the ADN Safety Committee available at: <http://www.unece.org/fileadmin/DAM/trans/doc/2016/dgwp15ac2/WP15-AC2-28-inf03e.pdf> and INF.30 submitted at the 29th session of the ADN Safety Committee available at: <http://www.unece.org/fileadmin/DAM/trans/doc/2016/dgwp15ac2/WP15-AC2-29-inf30e.pdf>.